

Message Text

UNCLASSIFIED

PAGE 01 KATHMA 01988 131109Z POSS DUPE
ACTION COME-00

INFO OCT-01 NEA-10 ISO-00 EB-07 PASS-00 /018 W
-----140650Z 098062 /11

R 130945Z MAY 77
FM AMEMBASSY KATHMANDU
TO SECSTATE WASHDC 8237

UNCLAS KATHMANDU 1988

E.O. 11652 N/A
TAGS: EGEN, BTIO, NP
SUBJ: KULEKHANI HYDRO-ELEC. DEV. TENDER NO 033/34-6

TO: GLENN BEAUPRE
MELLEY ENERGY SYSTEMS, INC.
P.O. BOX 999
POMPANO BEACH, FLORIDA 33061
TELEX: 51-4456

1. REFERENCE YOUR TEL REGARDING SUBJECT TENDER. SPECIFICATIONS:

1) ENGINE: EXHAUST TURBO-CHARGED TOTALLY ENCLOSED TYPE FOR OPERATION IN AN ADEQUATELY VENTILATED ROOM, WATER COOLED, MECHANICAL INJECTION, SINGLE ACTING, 4 STROKE INTERNAL COMBUSTION ENGINE RATED IN ACCORDANCE WITH B.S. 649 OR EQUIVALENT LATEST TO GET CONTINUOUS SITE OUTPUT OF 750 KW (MINIMUM) FROM THE ENGINE DRIVEN ELECTRICAL ALTERNATOR: SPEED - 750 RPM, MINIMUM SITE CONTINUOUS OUTPUT AFTER DERATING (IF APPLICABLE) - 1060 BHP AND OVERLOAD CAPACITY - 10PCT FOR ONE HOUR. 2) LUBRICATION: WET SUMP SYSTEM WITH INTEGRAL GEAR TYPE PUMPS PROVIDING A FORCED FEED TO ALL WORKING PARTS WITH A DUPLEX TYPE OF EQUIVALENT LUBRICATING OIL FILTER AND A CENTRIFUGAL TYPE FILTERS WITH PIPE WORK ON THE ENGINE WOULD INCORPORATE A COMPRESSED AIR OPERATED LUBRICATING OIL PUMPS. THE AMOUNT OF CONSUMPTION OF LUBRICATION OIL MUST BE SPECIFIED WITH THE TOLERANCE LIMIT OF PLUS MINUS 1PCT. 3) GOVERNING: HYDRAULIC CONST TYPE GOVERNOR OPERATING TO THE LIMITS LAIS DOWN
UNCLASSIFIED

UNCLASSIFIED

PAGE 02 KATHMA 01988 131109Z POSS DUPE

IN B.S. 649 HAND SPEED REGULATING GEAR WILL BE PROVIDED TO ENABLE THE SPEED OF THE ENGINES TO BE VARIED BY 5PCT UP OR DOWN FROM NORMAL WHILST THE ENGINE TO BE RUNNING AT ANY LOAD UP TO THE RATED LOAD. THE SPEED OF THE ENGINE WILL BE PROVIDED TO CONTROL FROM THE SWITCH BOARD. 4) FUEL CONSUMPTION: THE ENGINE MUST BE DESIGNED TO RUN ON DIESEL FUEL HAVING SPECIFICATIONS GIVEN. FUEL CONSUMPTION CURVE

SHOULD BE SUBMITTED. 5) FUEL SYSTEM:THE ENGINE SHALL BE COMPLETE WITH 3 - 4 CUBIC METER DAILY SERVICE FUEL TANKS HAVING A DIAL TYPE CONTENTS INDICATOR INSPECTING COVER, AND AN INLET BALL VALVE, SUITABLY INTERCONNECTED.

2. ALL BIDS MUST BE SUBMITTED VIA PURCHASED TENDER DOCUMENTS. BECAUSE OF JUNE 8 DEADLINE, IT WILL NOT BE POSSIBLE TO OBTAIN DOCUEMTNS AND SUBMIT IN TIME. INTERNATIONAL MAIL TAKES AT LEAST THREE WEEKS BOTH WAYS. IF YOU ARE SERIOUSLY INTERESTED, EMBASSY THEREFORE SUGGESTS THATYOU SEND AN AUTHORIZED REPRESENTATIVE TO HANDLE ON THE SPOT.EEAVES

NOTE BY OC/T: PASSED ABOVE ADDRESSEE.

UNCLASSIFIED

NNN

UNCLASSIFIED

PAGE 01 KATHMA 01988 160523Z
ACTION NEA-10

INFO OCT-01 ISO-00 PASS-00 /011 W
-----160604Z 014001 /20
R 130945Z MAY 77
FM AMEMBASSY KATHMANDU
TO SECSTATE WASHDC 8287

UNCLAS KATHMANDU 1988

E.O. 11652 N/A
TAGS: EGEN, BTIO, NP
SUBJ: KULEKHANI HYDRO-ELEC. DEV. TENDER NO 033/34-6

TO: GLENN BEAUPRE
MELLEY ENERGY SYSTEMS, INC.
P.O. BOX 999
POMPANO BEACH, FLORIDA 33061
TELEX: 51-4456

1. REFERENCE YOUR TEL REGARDING SUBJECT TENDER. SPECIFICATIONS:
1) ENGINE: EXHAUST TURBO-CHARGED TOTALLY ENCLOSED TYPE FOR OPERATION IN AN ADEQUATELY VENTILATED ROOM, WATER COOLED, MECHANICAL INJECTION, SINGLE ACTING, 4 STROKE INTERNAL COMBUSTION ENGINE RATED IN ACCORDIANCE WITH B.S. 649 OR EQUIVALENT LATEST TO GET CONTINUOUS SITE OUTPUT OF 750 KW (MINIMUM) FROM THE ENGINE DRIVEN ELECTRICAL ALTERNATOR: SPEED - 750 RPM, MINIMUM SITE CONTINUOUS OUTPUT AFTER DERATING (IF APPLICABLE) - 1060 BHP AND OVERLOAD CAPACITY - 10PCT FOR ONE HOUR. 2) LUB-

RICATION: WET SUMP SYSTEM WITH INTEGRAL GEAR TYPE PUMPS PROVIDING A FORCED FEED TO ALL WORKING PARTS WITH A DUPLEX TYPE OF EQUIVALENT LUBRICATING OIL FILTER AND A CENTRIFUGAR TYPE FILTERS WITH PIPE WORK ON THE ENGINE WOULD INCORPORATE A COMPRESSED AIR OPERATED LUBRICATING OIL PUMPS. THE AMOUNT OF CONSUMPTION OF LUBRICATION OIL MUST BE SPECIFIED WITH THE TOLERANCE LIMIT OF PLUS MINUS 1PCT. 3) GOVERNING: HYDRA-LIC CONST TYPE GOVENOR OPERATING TO THE LIMITES LAIS DOWN UNCLASSIFIED

UNCLASSIFIED

PAGE 02 KATHMA 01988 160523Z

IN B.S. 649 HAND SPEED REGULATING GEAR WILL BE PROVIDED TO ENABLE THE SPEED OF THE ENGINES TO BE VARIED BY 5PCT UP OR DOWN FROM NORMAL WHILST THE ENGINE TO BE RUNNING AT ANY LOAD UP TO THE RATED LOAD. THE SPEED OF THE ENGINE WILL BE PROVIDED TO CONTROL FROM THE SWITCH BOARD. 4) FUEL CONSUMPTION: THE ENGINE MUST BE DESIGNED TO RUN ON DIESEL FUEL HAVING SPECIFICATIONS GIVEN. FUEL CONSUMPTION CURVE SHOULD BE SUBMITTED. 5) FUEL SYSTEM: THE ENGINE SHALL BE COMPLETE WITH 3 - 4 CUBIC METER DAILY SERVICE FUEL TANKS HAVING A DIAL TYPE CONTENTS INDICATOR INSPECTING COVER, AND AN INLET BALL VALVE, SUITABLY INTERCONNECTED.

2. ALL BIDS MUST BE SUBMITTED VIA PURCHASED TENDER DOCUMENTS. BECAUSE OF JUNE 8 DEADLINE, IT WILL NOT BE POSSIBLE TO OBTAIN DOCUEMTNS AND SUBMIT IN TIME. INTERNATIONAL MAIL TAKES AT LEAST THREE WEEKS BOTH WAYS. IF YOU ARE SERIOUSLY INTERESTED, EMBASSY THEREFORE SUGGESTS THATYOU SEND AN AUTHORIZED REPRESENTATIVE TO HANDLE ON THE SPOT.EEAVES

NOTE BY OCT: PASSED ABOVE ADDRESSEE.

UNCLASSIFIED

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01-Jan-1994 12:00:00 am
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: HYDROELECTRIC POWER PLANTS, PROPOSALS (BID)
Control Number: n/a
Copy: SINGLE
Sent Date: 13-May-1977 12:00:00 am
Decaption Date: 01-Jan-1960 12:00:00 am
Decaption Note:
Disposition Action: n/a
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment:
Disposition Date: 01-Jan-1960 12:00:00 am
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1977KATHMA01988
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Expiration:
Film Number: D770170-0643
Format: TEL
From: KATHMANDU
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1977/newtext/t19770563/aaaacbko.tel
Line Count: 150
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: a0773895-c288-dd11-92da-001cc4696bcc
Office: ACTION COME
Original Classification: UNCLASSIFIED
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 3
Previous Channel Indicators: n/a
Previous Classification: n/a
Previous Handling Restrictions: n/a
Reference: n/a
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 13-Jan-2005 12:00:00 am
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 2539579
Secure: OPEN
Status: NATIVE
Subject: KULEKHANI HYDRO-ELEC. DEV. TENDER NO 033/34-6 TO: GLENN BEAUPRE MELLEY ENERGY SYSTEMS, INC.
TAGS: EGEN, BTIO, NP
To: STATE
Type: TE
vdkgvwkey: odb://SAS/SAS.dbo.SAS_Docs/a0773895-c288-dd11-92da-001cc4696bcc
Review Markings:
Margaret P. Grafeld
Declassified/Released
US Department of State
EO Systematic Review
22 May 2009
Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 22 May 2009